



NOTES:

1. THE DEPARTMENT WILL NOT BE RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING CAUSED BY RAIN OR STRUCTURAL FAILURE.
2. CONTRACTOR MUST LEAVE 3' OF WIRE OUT OF THE SERVICE HEAD.
3. ATTACHMENT POINT MUST BE ACCESSIBLE BY LADDER. SEE BWP DRAWING S-714.
4. CONTRACTOR MUST NOTIFY BWP OF ANY CHANGES MADE AFTER CONFIRMATION OF SERVICE THAT WOULD AFFECT SERVICE ATTACHMENT (ROOFLINE, ROOFING MATERIAL, WORKSPACE, ETC.).
5. ELECTRICAL SERVICE EQUIPMENT MUST HAVE MINIMUM 3' LATERAL CLEARANCE FROM ANY GAS LINE.
6. NO 120 VOLT LOAD SHALL BE CONNECTED ON 240 VOLT OR 480 VOLT 3-PHASE DELTA SERVICES.

						BURBANK WATER AND POWER – ELECTRIC SERVICES	
						PERISCOPE SERVICE COMMERCIAL 100, 200 AMP PANELS INSTALLATION WITH SUPPORT RACK	
B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	WATER AND POWER		
A	REMOVE NOTE	SP	RS	2/14/18			
No.	REVISIONS	BY	APPR'V'D	DATE			
							Sheet 1 of 1