

# MULTI-UNIT APARTMENTS

**BWP WILL NOT INSTALL METERS UNTIL THE LABELING IS COMPLETE IN ACCORDANCE WITH BWP RULES AND REGULATIONS. FOR LATEST STANDARDS, REFERENCE THE LATEST RULES AND REGULATIONS SECTION 2.68.**

WHERE MULTIPLE METERS ARE INSTALLED, THEIR VERTICAL CENTER SHALL BE A MINIMUM OF 8 1/2 INCHES APART AND THEIR HORIZONTAL CENTER SHALL BE A MINIMUM OF 7 1/2 INCHES APART FOR SINGLE-PHASE METERS. SAFETY SOCKET BOXES SHALL HAVE A MINIMUM SPACE OF 1/2 INCH BETWEEN BOXES HORIZONTAL AND VERTICAL. ALL METERS MUST BE INSTALLED TO COMPLY WITH EUSERC DRAWINGS 353, G-2, AND G-3.

SEALABLE PULL-BOXES AND GUTTERS SHALL BE USED FOR ALL MULTIPLE METER INSTALLATIONS.

MULTIPLE METER PERMANENT ADDRESS/UNIT LABELING MUST BE PROVIDED AS LISTED BELOW:

WEATHER PROOF TAGS WITH 1/4 INCH MINIMUM ENGRAVED NUMBERS AND SHALL BE RIVETED IN PLACE. THE ENGRAVING SHALL BE DEEP ENOUGH TO PREVENT IT FROM BEING OBSCURED BY PAINTING.

WEATHER PROOF 3/4 INCH MINIMUM HEIGHT NUMBER STICKERS DESIGNED FOR OUTDOOR USE.

WEATHER PROOF PAINT STENCILED NUMBERS 3/4 INCH MINIMUM HEIGHT.

NOT ACCEPTABLE: PERMANENT INK MARKERS LIKE MARK-A-LOT OR SHARPIE.


IF THE SERVICE EQUIPMENT SERVES MORE THAN ONE STREET ADDRESS, THE LABELING SHALL INCLUDE THE STREET ADDRESS.

IF THE MAIN BREAKERS ARE NOT INSTALLED DIRECTLY ADJACENT TO THE METERS, THE METER AND THE MAIN BREAKER SHALL BE IDENTIFIED WITH INDIVIDUAL LABELS.

METERS WILL NOT BE INSTALLED UNTIL THE LABELING IS COMPLETE.

UNIT NUMBERING MUST MEET BURBANK MUNICIPAL CODE REQUIREMENTS SECTIONS 9-1-0-505.1.1 THROUGH 9-1-9-505.1.3.

BEFORE BWP WILL ENERGIZE NEW SERVICES ADDRESS LABELS AT THE FRONT OF THE BUILDING AND AT ANY ALLEY MEETING 9-1-9-505.1.3 (PREMISES IDENTIFICATION) MUST BE IN PLACE. ADDITIONALLY INDIVIDUAL UNITS MUST BE LABELLED AND HOMERUNS TO EACH UNIT INSTALLED TO ALLOW FOR METER RING OUT VERIFICATION. HOMERUNS AND UNIT LABELLING MUST MATCH LABELLING AT THE PANEL.

						<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
						MULTI-UNIT APARTMENTS	DRAWING No.
A	STANDARDIZED FORMATTING	MEP	CJC	5/9/23		S-825A	
No.	REVISIONS	BY	APP'V'D	DATE			Sheet 1 of 1