


## 4' X 4'-6" SINGLE PHASE TRANSFORMER PAD CLEARANCES REQUIREMENTS

**NOTES:**

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. REFER TO DRAWINGS S-464 AND S-821 FOR INSTALLATION AND GROUNDING DETAILS.
3. REDUCED CLEARANCE REQUESTS MAY BE CONSIDERED ON A CASE BY CASE BASIS FOR LOW-HEIGHT RESIDENTIAL RETAINING WALLS AROUND SINGLE PHASE PADMOUNT TRANSFORMERS. SEE DRAWING S-464. WRITTEN PRE-APPROVAL BY BWP REQUIRED.
4. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

					 <b>CITY OF BURBANK</b> <b>WATER AND POWER</b>	<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
						CLEARANCES REQUIREMENTS 4'x4'-6" SINGLE PHASE TRANSFORMER PAD	
B	ADDED NOTE 4	MEP	SK	9/26/23			
A	NEW DRAWING	MEP	CJC	5/9/23			
No.	REVISIONS	BY	APPR'V'D	DATE			
							Sheet 1 of 1