


**NOTES:**

1. BEFORE STARTING ANY CONSTRUCTION AND ORDERING ANY MATERIALS, CONTRACTOR MUST CALL BWP INSPECTOR AT (818) 238-3590 FOR A PRECONSTRUCTION MEETING AT LEAST 48 HOURS IN ADVANCE TO DISCUSS BWP CONSTRUCTION REQUIREMENTS.
2. SLAB-BOX TO BE PLACED ON A MINIMUM OF 6" OF CRUSHED ROCK. EXCAVATION AROUND IT TO BE FILLED WITH SLURRY.
3. PRIOR TO INSTALLING, CONTACT BURBANK WATER AND POWER CONDUIT MECHANIC/INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 24 HOURS IN ADVANCE.
4. THE CONTRACTOR MUST INSTALL THE GROUND RODS AND GROUNDING SYSTEM CALLED FOR IN THIS STANDARD WHILE IN THE PRESENCE OF THE BWP INSPECTOR AND TO THE SATISFACTION OF THOSE REQUIREMENTS DETAILED IN THE LATEST VERSION OF THE NATIONAL ELECTRICAL CODE, ARTICLES 250-83 AND 250-84. REFER TO DRAWING S-821 FOR GROUNDING DETAILS.

G	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	 <b>WATER AND POWER</b>	BURBANK WATER AND POWER – ELECTRIC SERVICES	
F	REVISED NOTES	NHS	DDB	7/22/09		<b>CABLE BOX WITH SLAB FOR PADMOUNTED SWITCH CABINET</b>	DRAWING No.
E	REVISED NOTES #3 AND #4	PL	DDB	2/10/03			<b>S-462G</b>
D	REVISED SIDE CLEARANCE	WAW	GLS	8/27/97			Sheet 1 of 1
No.	REVISIONS	BY	APPR'V'D	DATE			