



**NOTES:**

1. BWP WILL NOT BE RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING CAUSED BY RAIN OR STRUCTURAL FAILURE.
2. CONTRACTOR MUST LEAVE 3' OF WIRE OUT OF THE SERVICE HEAD.
3. ATTACHMENT POINT MUST BE ACCESSIBLE BY LADDER. SEE BWP DRAWING S-714.
4. CONTRACTOR MUST NOTIFY BWP OF ANY CHANGES MADE AFTER CONFIRMATION OF SERVICE THAT WOULD AFFECT SERVICE ATTACHMENT (ROOFLINE, ROOFING MATERIAL, WORKSPACE, ETC.).
5. ELECTRICAL SERVICE EQUIPMENT MUST HAVE MINIMUM 3' LATERAL CLEARANCE FROM ANY GAS LINE.
6. SERVICE DROP MUST HAVE MINIMUM 3' CLEARANCE FROM ANY WINDOWS, DOORS, ROOF ACCESS LADDERS, ETC.

						<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
						DRAWING No.	
B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	<b>PERISCOPE SERVICE RESIDENTIAL BELOW EAVES ATTACHMENT</b>		<b>S-727B</b>
A	CHANGED CLEARANCE BELOW EAVES	DSL		5/6/08			
No.	REVISIONS	BY	APPR'V'D	DATE			Sheet 1 of 1