



**6' X 8'-6" THREE PHASE TRANSFORMER
PAD CLEARANCES REQUIREMENTS**

NOTES:

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

						BURBANK WATER AND POWER – ELECTRIC SERVICES	
B	ADDED NOTE 2	MEP	SK	9/26/23		DRAWING No.	
A	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	6'x8'-6" THREE PHASE TRANSFORMER PAD		S-724B
	NEW DRAWING	NHS		2/1/08			
No.	REVISIONS	BY	APPR'V'D	DATE	WATER AND POWER		