


**NOTES:**

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

				CITY OF BURBANK		BURBANK WATER AND POWER - ELECTRIC SERVICES	
B	ADDED NOTE 2	MEP	SK	9/26/23	 <b>WATER AND POWER</b>	<b>SWITCH &amp; TRANSFORMER PAD REQUIRED CLEARANCES ORIENTATION PLAN No. 1</b>	DRAWING No.
A	STANDARDIZED FORMATTING/UPDATE CLEARANCES	MEP	CJC	5/9/23			<b>S-600B</b>
	NEW DRAWING	MJK	GLS	8/8/96			
No.	REVISIONS	BY	APPR'V'D	DATE			Sheet 1 of 1