



**8' X 10'-6" THREE PHASE TRANSFORMER
PAD CLEARANCE REQUIREMENTS**

NOTES:

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

					BURBANK WATER AND POWER – ELECTRIC SERVICES	
B	ADDED NOTE 2	MEP	SK		9/26/23	DRAWING No.
A	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	CLEARANCE REQUIREMENTS 8'x10'-6" THREE PHASE TRANSFORMER PAD	
	NEW DRAWING	NHS		2/1/08	S-725B	
No.	REVISIONS	BY	APPR'V'D	DATE	Sheet 1 of 1	