


**NOTES:**

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 24 HOURS IN ADVANCE.
2. THE CONTRACTOR MUST INSTALL THE GROUND RODS AND GROUNDING SYSTEM CALLED FOR IN THE STANDARD WHILE IN THE PRESENCE OF THE BWP INSPECTOR AND TO THE SATISFACTION OF THOSE REQUIREMENTS DETAILED IN THE LATEST VERSION OF THE NATIONAL ELECTRICAL CODE, ARTICLES 250-83 AND 250-84.
3. BACKFILL SOIL IS TO BE COMPACTED TO PREVENT MOVEMENT OR SLIPPAGE OF THE SLAB OR BOX.
4. REFER TO DRAWING S-821 FOR GROUNDING DETAILS.

						<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
						9' X 15' TRANSFORMER PAD DETAILS	
							DRAWING No.
							<b>S-671B</b>
							Sheet 1 of 1
B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23			
A	REVISED CABLE OPENING	HB	DDB	6/18/99			
No.	REVISIONS	BY	APPR'V'D	DATE			